

Certificate of Compliance

Certificate Number(s):

UL-US-2579544-0

Report Reference:

E549307-20250808

Issue Date:

2025-08-11

Issued to:

European Safety Systems Ltd
Impress House, Mansell Rd., London, W3 7QH, GB

This certificate confirms that representative samples of:

UXVD - Audible-signal Appliances, Fire Alarm, for Use in Zone
Classified Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 464, Edition 11, Issue Date 2023-04-28

UL 60079-1, Edition 7, Issue Date 2015-09-18, Revision Date 2024-04-22

UL 60079-0, Edition 7, Issue Date 2019-03-26, Revision Date 2024-07-19

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2579544-0
Report reference: E549307-20250808
Issue Date: 2025-08-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Alarm Signaling Equipment for HazLoc

Model(s): GNEEx, : GNEExS2HDC024-A, GNEExS1RDC024-A, GNEExS1FDC024-A, GNEExS1RDC024-S, GNEExS2FDC024-S, GNEExS2FDC024-A, GNEExS1FDC024-S, GNEExS2HDC024-S



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number(s):

UL-CA-2558404-0

Report Reference:

E549307-20250808

Issue Date:

2025-08-11

Issued to:

European Safety Systems Ltd
Impress House, Mansell Rd., London, W3 7QH, GB

This certificate confirms that representative samples of:

**UXVD7 - Audible-signal Appliances, Fire Alarm, for Use in Zone
Classified Hazardous Locations Certified for Canada**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

ULC 525:2023, 5th Ed., Issue Date: 2023-04-28
CSA C22.2 No. 60079-0, Edition 4, Issued 2019-02-01
CSA C22.2 NO. 60079-1, 3rd Ed., Issue Date: 2016-05-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2558404-0
Report reference: E549307-20250808
Issue Date: 2025-08-11

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Alarm Signaling Equipment for HazLoc

Model(s): GNEEx, : GNEExS2HDC024-A, GNEExS1RDC024-A, GNEExS1FDC024-A, GNEExS1RDC024-S, GNEExS2FDC024-S, GNEExS2FDC024-A, GNEExS1FDC024-S, GNEExS2HDC024-S



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

