



شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	25-06-154207/E25-06-160050/NB0007	رقم الشهادة:
Registration Date:	20/06/2025	تاريخ التسجيل:
Valid Until:	19/06/2026	صالحة لغاية:
Issued To:	TELECTRON AGENCIES & TRADING - L.L.C - O.P.C P.O. Box 2946 ,1001 Lulu Centre Building AL SALAM STREET Abu Dhabi ,United Arab Emirates	أصدرت إلى :
Sector:	Electrical	قطاع: كهرباء
Product Category:	ECAS-Ex	تصنيف المنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Sub-Category:	ECAS-Ex	التصنيف الفرعي للمنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات

intertek
Total Quality. Assured.
جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

600565554

www.moiat.gov.ae

[Instagram](https://www.instagram.com/moiat) [Facebook](https://www.facebook.com/moiat) [YouTube](https://www.youtube.com/moiat) [LinkedIn](https://www.linkedin.com/moiat) @MoIAT



تم اصدار هذا المستند الكترونيا ولا يحتاج إلى ختم أو توقيع.
This document has been issued electrocically and doesn't require a stamp and signature.



بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

Company Name: TELETRON AGENCIES & TRADING - L.L.C - O.P.C اسم الشركة:
Product Category: ECAS-Ex الأجهزة الكهربائية المعدة للاستخدام
في الأجواء القابلة للانفجار تصنيف المنتج:
Certificate No.: 25-06-154207/E25-06-160050/NB0007 رقم التسجيل:
Registration Date: 20/06/2025 تاريخ التسجيل:
Valid Until: 19/06/2026 صالح لغاية:

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/ Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
--------	-----------------------------------	--------------------------------	-------------------------------------	-----------------------------------	-------------------------------------	---------------------	---	---------------------------------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

1	E2S	BExCP3A	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb IIC T6 Gb Ta = (-40°C +70°C); Ex tb III C T75°C Db Ta = (-40°C +70°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	---------	---	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

2	E2S	BExCP3B	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C +50°C); Ex tb III C T60°C Db Ta = (-40°C +50°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	---------	--	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

3	E2S	BExCP3C	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C +65°C); Ex tb III C T75°C Db Ta = (-40°C +65°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	---------	--	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

4	E2S	BExCP3D	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C +70°C); Ex tb III C T80°C Db Ta = (-40°C +70°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	---------	--	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

5	E2S	BExCP3E	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C +65°C); Ex tb III C T75°C Db Ta = (-40°C +65°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	---------	--	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

6	E2S	GNExCP6A	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb IIC T6 Gb Ta = (-40°C +70°C) Ex tb III C T75°C Db Ta = (-40°C +70°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	----------	--	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

7	E2S	GNEExCP6B	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C +50°C); Ex tb III C T80°C Db Ta = (-40°C +50°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	-----------	--	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

8	E2S	GNExCP6C	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C to +65°C); Ex tb IIIC T75oC Db Ta = (-40°C to +65°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	----------	---	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

9	E2S	GNExCP6D	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C to +70°C); Ex tb IIIC T80oC Db Ta = (-40°C to +70°C); Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
---	-----	----------	---	-----	--	---	---	----------------



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

10	E2S	GNEExCP6E	Manual Call Point; Types of Protection: Increased safety, flameproof, encapsulation and dust; Markings: Ex db eb mb IIC T4 Gb Ta = (-40°C to +65°C); Ex tb IIIC T75oC Db Ta = (-40°C to +65°C) Refer to IECEx SIR 09.0121X annex for more details.	N/A		IECEX SIR 09.0121X GB/SIR/ExTR09.0195/00 GB/SIR/ExTR11.0326/00 GB/SIR/ExTR11.0326/01 GB/SIR/ExTR16.0151/00 GB/SIR/ExTR17.0236/00 GB/SIR/ExTR19.0331/00 GB/SIR/ExTR20.0143/00 GB/SIR/QAR06.0020/13	UAE.S IEC 60079-18, UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	United Kingdom
Nothing Follows								



Total Quality. Assured.

جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



مطابق
COMPLIANT

